

ENSURE THE SAFETY OF YOUR PEOPLE, PROPERTY, PRODUCTIVITY, PROFITABILITY AND ASSETS!

DESCRIPTION	INSPECTION/TEST FREQUENCY	CODE REFERENCE
FIRE ALARM SYSTEMS (OPERATIONAL SYSTEM TEST AND CERTIFICATION)		
Control Panels, Power Supplies, Annunciators	Annual	NFPA 72
Fire Alarm Notification Appliances	Annual	NFPA 72
Fire Alarm Initializing Appliances	Annual	NFPA 72
Fire Alarm Supervisory Appliances	Semi-Annual	NFPA 72
Battery Load Testing	Semi-Annual	NFPA 72
Smoke Detector Sensitivity Testing	Every 2-5 Years	NFPA 72
FIRE SPRINKLER SYSTEMS		
Sprinkler System Inspections	Annual / Quarterly	NFPA 25
Sprinkler System Internal Service	Every 5 Years	NFPA 25
Backflow Inspection and Service	Annual	NFPA 25
Standpipe System Inspections	Every 5 Years	NFPA 25
Standpipe System Service	Semi-Annual	NFPA 25
Fire Hydrant Service	Annual / 5 Years	NFPA 25
Fire Pump Service	Annual	NFPA 25
FIRE EXTINGUISHERS		
Visual Inspection — All Types	Monthly	NFPA 10
Maintenance and Certification — All Types	Annual	NFPA 10
Empty and Maintain — Dry Chemical Extinguishers	Every 6 Years	NFPA 10
Empty and Maintain — Halon/Halotron Extinguishers	Every 6 Years	NFPA 10
Hydrostatic Inspection — CO2, Wet Chemical	Every 5 Years	NFPA 10
Hydrostatic Inspection — Dry Chemical, Halon/Halotron	Every 12 Years	NFPA 10
RESTAURANT AND INDUSTRIAL SYSTEMS		
Inspection and Certification	Semi-Annual	NFPA 17, 17A
EMERGENCY AND EXIT LIGHTING		
90 Minute Battery Testing	Annual	NFPA 101